

Hurricane Fire & Rescue

Hurricane, WV

Operation Guidelines

Subject
Guideline Number
Adopted
Effective Date
Pages

Nozzles
800.503
March 1, 2007
April 7, 2007
1

Purpose: This procedure identifies the procedure for nozzle maintenance and cleaning.

Scope: All personnel

Responsibility: It is the responsibility of all personnel to adhere to this guideline.

- A. All nozzles will be removed from pre-connects, master stream devices and compartments during apparatus checks on the second Thursday of each month for inspection/cleaning.
- B. Nozzles will be cleaned by immersing them in soapy water and operating all moving parts. They will then be rinsed and dried. Proper operation of shut off and pattern adjustment will be noted.
- C. Lubricate nozzles with WD40 or designated lubricant as needed.

NOTE: To keep apparatus in service for fire fighting, do not remove all nozzles at the same time.