

Hurricane Fire & Rescue

Hurricane, WV

Administration
Guidelines

Subject
Guideline Number
Adopted
Effective Date
Pages

Pump Testing
800.506
March 1, 2007
April 7, 2007
1

Purpose: This guideline identifies the procedure for pump testing apparatus.

Scope: Project Coordinator

Responsibility: It is the responsibility of the Maintenance Officer to ensure compliance with this policy.

All fire apparatus with pump capabilities will be pump tested per NFPA 1911. Each apparatus will be tested in the month of August annually. The Chief will maintain all records.